

CERTIFICATION LETTER

We certify that ExoAir Duo has been tested in accordance with ASTM test methods and the following data are the results of the most recent testing:

ASTM D 412

Tensile	40 psi
Elongation	50%

ASTM E 84 (adhered with Spectrem 1 Silicone Sealant)

Flame Spread	5
Smoke Development	55

ASTM E 90 (Testing in a 5/8" joint in combination with ExoAir LEF and ExoAir Eco Membrane)

STC rating	50
OITC rating	28